#### **Electrical Data/Hazardous Area Classifications**

## ATEX Directive 94/9/EC


Since 1st July 2003 the ATEX Directive 94/9/EC has required equipment and protective systems that are for use in potentially explosive atmospheres, to conform to specific safety standards. The directive is applicable to all countries within the EU.

#### **Equipment Marking**

The following is a guide only to the identification markings on ATEX marked equipment and protective systems.

Determining the suitability of ATEX marked equipment and safety systems is the responsibility of the user.

### EU Directive 94/9/EC from July 1, 2003 — Table 1



#### Methods of Protection—Table 2

Method of protection	Marking	Protection principle			
Electrical equipment for gases, vapours and mists according to CENELEC					
Flameproof enclosure	EEx d	Contain the explosion and prevent flame propagation			
Increased safety	EEx e	No arcs, sparks, or hot surfaces			
Nonsparking	EEx n	No arcs, sparks, or hot surfaces			
Intrinsic safety	EEx i	Limit the energy of the spark and surface temperature			
Oil immersion	EEx o	Keep the ignition source constantly immersed in oil			
Pressurised enclosure	EEx p	A protective gas contains the ignition source			
Sand filling	EEx q	Fine ground filling surrounds the ignition source and therefore, an arc from inside of the housing cannot ignite the surrounding combustible atmosphere			

#### Classification of Gases and Dusts per CENELEC/IEC—Table 3

Gas group	Temperature class							
	T1	T2	Т3	T4	T5	Т6		
I	Methane	_	_	_	_	_		
IIA	Acetone Methane Ethane Propane	Ethyl alcohol Cyclohexane n-butane n-butyl alcohol	Diesel fuel Aircraft fuel Fuel oil <i>n</i> -hexane Heptane	Acetaldehyde	_	_		
IIB	Coal (lighting) gas Acrylonitrile	Ethylene Ethylene oxide	Ethylene glycol Hydrogen sulphide	Ethyl methyl ether	_	_		
IIC	Hydrogen	Ethine (Acetylene)	_	_	_	Carbon disulfide		

#### Temperature Classification—Table 4

CENELEC/IEC (Group II) Class	Max surface temperature	Comments			
T1	450°C (842°F)				
T2	300°C (572°F)	Temperature relates to			
T3	200°C (392°F)	all parts of equipment that can come into contact with the potentially explosive atmosphere			
T4	135°C (275°F)				
T5	100°C (212°F)				
T6	85°C (185°F)				
Tx	Maximum surface	Assessment of equipment temperature			
	temperature not defined	class is the responsibility of the user			

#### Example equipment marking:



ATEX Category 2 (gas) equipment designated for installation in Zone 1. Protection by flameproof enclosure, suitable for hydrogen atmosphere with maximum equipment surface temperature of 100°C.

#### Equipment Groups I and II: Categories M1, M2, 1, 2, and 3—Table 5

<b>Group I</b> Mines: methane and/or combustible dusts		<b>Group II</b> Above ground: potentially explosive atmospheres or gas/air or dust/air mixtures, mist or vapours					
Category M		Category 1		Category 2		Category 3	
1	2	<b>G</b> (Gas) (Zone 0)	<b>D</b> (Dust) (Zone 20)	<b>G</b> (Gas) (Zone 1)	<b>D</b> (Dust) (Zone 21)	<b>G</b> (Gas) (Zone 2)	<b>D</b> (Dust) (Zone 22)
Equipment which guarantees a very high degree of safety. Operation guaranteed in case of errors.	Equipment which guarantees a very high degree of safety. Switching off possible if potentially explosive atmosphere occurs.	For equipment which guarantees a very high degree of safety. Intended for cases where potentially explosive atmospheres are often or constantly to be expected.		For equipment which guarantees a high degree of safety. Intended for cases where a potentially explosive atmosphere is to be expected.		For equipment which guarantees a standard degree of safety. Intended for cases where a potentially explosive atmosphere can be expected only rarely, and then, only for a short time.	
Very high protection level	High protection level	Very high protection level		High protection level		Normal	

# National Electrical Code (NEC) Hazardous Area Classifications

CLASS I: Areas where flammable gases or vapors may be present in the air in sufficient quantities to be explosive

Group A: Atmospheres containing acetylene

**Group B:** Atmospheres such as butadiene, ethylene oxide, propylene oxide, acrolein, or hydrogen (or gases or vapors equivalent in hazard to hydrogen, such as manufactured gas)

**Group C:** Atmospheres such as cyclopropane, ethyl ether, or ethylene (or gas or vapors of equivalent hazard)

**Group D:** Atmospheres such as acetone, alcohol, ammonia, benzene, benzol, butane, gasoline, hexane, lacquer solvent vapors, naphtha, natural gas, propane, or gas or vapors of equivalent hazard

CLASS II: Areas made hazardous by the presence of combustible dust

Group E: Atmospheres containing combustible

- 1) metal dusts, regardless of resistivity
- 2) dust of similarly hazardous characteristics having a resistivity less than 100 kΩ-cm
- 3) electrically conductive dusts

Group F: Atmospheres containing combustible

- 1) carbon black, charcoal, or coke dusts having more than 8% total volatile material
- 2) dusts so sensitized that they present an explosion hazard, and dusts having a resistivity greater than 100  $\Omega$ -cm but less than or equal to 1 x 108  $\Omega$ -cm

**Group G:** Atmospheres containing combustible

- 1) dust having resistivity equal to or greater than 100 k $\Omega$ -cm
- 2) electrically nonconductive dusts

CLASS III: Areas made hazardous by the presence of easily ignitable fibers or dust, but which are not likely to be suspended in the air in sufficient quantities to ignite

Division 1: Atmospheres where hazardous concentrations exist continuously, intermittently, or periodically under normal operating conditions

Division 2: Atmospheres where hazardous concentrations exist only in case of accidental rupture or breakdown of equipment

**EXPLOSION-PROOF:** Enclosures or housings are designed to withstand internal explosions and prevent the spread of fire to the outside.

INTRINSICALLY SAFE: Systems in which electrical energy in the circuits is not present at levels that would ignite a flammable mixture of a gas and air.

US Toll-free: 800-323-4340 • Outside the US: 1-847-549-7600 • www.coleparmer.com